

AJMER VIDYUT VITRAN NIGAM LIMITED, SIKAR,
(SIKAR CIRCLE)

No. AVVNL/SE/SC/T/A/Tech/F. /D. 2013 Dated: 23-03-2012

The Executive Engineer (Rural)
Ajmer Discom,
Sikar.

**Sub:- Sanction to the estimate for increasing of load 24 KW to 60KW in respect
of applicant/consumer M/s Paliwala Vocational Training & Research
Institute, Basni Road, Banjara Basti Laxmangarh bearing A/C No. 0591-007
(Mixed load) under the AEN (O&M) AVVNL, Laxmangarh**

Ref:- (i) Your office letter No. 1593 dated 25.01.2012 & 1398 dt. 13.03.2012.

With reference to above, Sanction of the S.E. (S/C) AVVNL, Sikar is hereby conveyed to the estimate as proposed & as recommended by you for installation of 1K100 KVA S/S in place of existing 1X40 KVA S/S with laying of 11 KV X LPE cable 30 meters by applicant & Installation of 11 KV metering equipments by the Nigam for increasing of load 24 KW to 60KW in respect of applicant/consumer M/s Paliwala Vocational Training & Research Institute, Basni Road, Banjara Basti, Laxmangarh bearing A/C No. 0591-007 (Mixed load) under the AEN (O&M) AVVNL,Laxmangarh in view of his an application dated 24.11.2011.

Sanction is subject to the following terms & conditions:-

1. The Supervision charges and security of 11 KV metering equipments are to be recovered as per the rules of Nigam through D.N.
2. 11KV metering equipments be installed in presence of the XEN (MT) AVVNL Sikar.
3. 11 KV line & S/S be commissioned after approval of the Electrical Inspector, Govt. of Rajasthan.
4. All other codal formalities be completed before increasing the load.

IA to Superintending Engineer (SC)
AVVNL, Sikar.

→ Copy to the Assistant Engineer (O&M) AVVNL, Laxmangarh for information and necessary action.

Encl:- 2 No. case file

IA to Superintending Engineer (SC)
AVVNL, Sikar.